

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SCHOOL SANITARY CERTIFICATE FOR 2022- 2023

(Academic Year)

(Under the Tamil Nadu Education Rules)

L.Dis. No: E1 / 001668 / 2022

Appendix – 3

Date: 17/03/2022

Chapter III Rule - 24

I hereby declare that I have inspected the **MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL** Building and Premises Located at No.162/1, Gudapakkam Village, Chennai-600124, Poonamallee Taluk, Thiruvallur District on the **Thursday 17th March 2022** and certify.

- That the accommodation provided for each of the several classes is sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted.
- That the building is maintained in substantial repair.
- That is neat and clean.
- That the latrine arrangements are adequate and satisfactory.
- That the supply of drinking water is whole some and Safe.
- That in all other necessary respects that sanitation is good.
- Dengue Awareness and Prevention Sign board should be display in the size of 6X3 visibly around the school Premises

This Certificate Valid for the period of One year from the date of Issue

COUNTER SIGNED

M. S. K. K. K. K.
DEPUTY DIRECTOR OF PH & PM
INSTITUTE OF PUBLIC HEALTH
POONAMALLEE,
CHENNAI-600 058.

H. L. H. H.
Mrs. LATHA HARIHARAN
PRINCIPAL
MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Tiruvallur District, Chennai-600124.

S. S. S. S.
BLOCK HEALTH SUPERVISOR
GOVT PRIMARY HEALTH CENTRE
NEMAM-IPH-POONAMALLEE
THIRUVALLUR DISTRICT

P. P. P. P.
Mr. PRAVEEN KUMAR TATIA
SECRETARY
MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Tiruvallur District, Chennai - 600 124.

Telephone: 22501028.



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

R.No.550/C/2021 Misc - 112

Dated: 18.03.2021

From :

Tmt.L.Sujatha M.Sc.,M.A.B.Ed.,
CHIEF WATER ANALYST,
Chief Water Analysis Laboratory,
King Institute Campus, Guindy,
Chennai-600 032.

To :

✓ Principal,
Mahaveer Rajasthani
International School,
Gudapakkam, Poonamallee Taluk,
Thiruvallur District, Chennai - 600 124

Sir,

Subject: Report on examination of water samples - regarding.

A sample of water stated to have been collected on 04.03.2021 from a bore well by Mr.P.Vignesh at the premises of Mahaveer Rajasthani International School, Gudapakkam, Poonamallee, Chennai - 600 124 was received at this laboratory on the same day from the addressee to assess their suitability for drinking purposes.

The results of analysis are furnished overleaf.

The sample of bore well water is colourless and clear in physical appearance.

Chemical analysis reveals that it is hard and is of acceptable quality for drinking purposes.

Bacteriological quality is also of satisfactory on this occasion.

Copy to : Lab & File

[Signature]
CHIEF WATER ANALYST

[Signature]
22/3/2021

[Signature]
Mrs. LATHA HARIHARAN
PRINCIPAL
MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Thiruvallur District, Chennai-600124.

[Signature]
Mr. PRAVEEN KUMAR TATIA
SECRETARY
MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Thiruvallur District, Chennai - 600 124.

RESILTS OF EXAMINATION OF SAMPLES OF WATER

From : Mahaveer Rajasthani Internation School, Gudapakkam, Poonamallee, Chennai -124

Collected by : Thiru.P.Vignesh Misc- 112

Date of Collection : 04.03.2021		Bore well water at the above premises		Maximum permissible limit for drinking water as per BIS 10500/1991	
Date of Receipt : 04.03.2021					
Source as per label					
Bacteriological Examination	Total colonies per ml on agar at 37°C	5		20	
	MPN of Coliform bacteria per 100 ml.	0		0	
	Nature of coliform bacteria isolated			absent	
	Results of vibrio test				
Physical Examination	Colour	Colourless		Colourless	
	Turbidity (Units)	5		10	
	Smell	None		None	
Chemical Examination (in mg/l)	Total dissolved Solids	690		2000	
	Carbonate hardness as CaCO ₃	260		-	
	Non- Carbonate hardness as CaCO ₃	92		-	
	Total hardness as CaCO ₃	352		600	
	Chloride as Chlorine	116		1000	
	Ammoniacal nitrogen	-		Nil	
	Albuminoid nitrogen	-		Nil	
	Oxygen absorbed (Tidy's test)	0.08		-	
	Nitrate-nitrogen	2.0		10	
	Alkalinity	0		-	
	as CaCO ₃	Phenolphthalein Methyl Orange	260		600
			0.2		1.5
	Fluoride as Fluorine			6.5-8.5	
	PH	6.9			
	Iron as Fe Total	0.05		0.3	
	Ferrous	Nil		Nil	
	Manganese as Mn.	Nil		0.3	
	Qualitative- Nitrite nitrogen			Trace	
	Sulphate	Trace		400	
	Phosphate	Trace		Trace	
	Toxic substances				
Electrical conductivity (Reciprocal megohms Cm ² at 20°C)	980				
Microscopical Examination		Amorphous matter			

Mrs. LATHA HARIHARAN
PRINCIPAL

MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Tiruvallur District, Chennai-600124.

Mr. PRAVEEN KUMAR TATIA
SECRETARY

MAHAVEER RAJASTHANI INTERNATIONAL SCHOOL
Gudapakkam, Poonamallee Taluk,
Tiruvallur District, Chennai - 600 124.